

# Certificate



Aktiengesellschaft

No. z2556b-11-E

## Customer:

Fischer-J.W. Zander GmbH & Co. KG  
Käppelesäcker 10  
D-74235 Erlenbach

## Test sample(s):

- Connector:  
**ZA-TEC Modul RJ45, Cat.6<sub>A</sub>, shielded 10GE, Re-Embedded tested**  
Part-No.: 9072244

## Applied standard(s):

- ISO/IEC 11801 AMD2 (2010-04)
- IEC 60603-7-51 - Ed. 1.0 (2010-03)

## Results:

Up to a bandwidth of **500 MHz** the sample meet the **Category 6<sub>A</sub>** limits of the specified standards and regulations.

## Connector, Category 6<sub>A</sub>

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report, no. **P2556b-11-E**, from **April 27<sup>th</sup>, 2011** and shall only be applicable in conjunction with the test report.

Bexbach, April 27<sup>th</sup>, 2011

Dirk Wilhelm, engineer  
(Chairman of the Managing Board)



GHMT AG  
In der Kolling 13  
D-66450 Bexbach  
Phone: +49 (0) 68 26 / 92 28 – 0  
Fax: +49 (0) 68 26 / 92 28 – 99  
Email: info@ghmt.de